

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 97044
 Permit No. _____
 Basin 099
 NOTICE OF INTENT NO. 49866

PRINT OR TYPE ONLY

1. OWNER John Preku
 MAILING ADDRESS 639 Isbell St. #280
Reno, NV 89509
 ADDRESS AT WELL LOCATION 21900 Fetlock Drive
Reno, NV 89506

2. LOCATION SE SW 33 24 18 Washoe
 PERMIT NO. N/A 078-302-21

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Brown DG with thin brown clay layers		17	160	143
Red Ledge Rock		160	162	2
Brown DG with thin brown clay layers		162	212	50

8. WELL CONSTRUCTION
 Depth Drilled 212 Feet Depth Cased 212 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 18 Feet
10 Inches 18 Feet 212 Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8 steel	14	.188"	-1'	17'
6 5/8" PVC	4.95	.390"	17'	212'

Note:
 PLEASE BE ADVISED THAT THIS WELL BEGAN TO ARTESIAN 1st OF MARCH 2006 SO WE WELDED 2' OF 6 5/8" ONTO EXISTING 1' OF STICK UP ABOVE GROUND LEVEL.
Bruce Miller

Perforations:
 Type perforation Mill Slot
 Size perforation .032"
 From 140 feet to 180 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 212 feet

Date started 5-26, 20 05
 Date completed 5-28, 20 05

7. WELL TEST DATE

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>70</u>	<u>200</u>	<u>4</u>
Approx			

9. WATER LEVEL
 Static water level Ground level feet below land surface
 Artesian flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MILLER & SONS DRILLING CO.
 Address P.O. Box 8056
Reno, NV 89507
 Nevada contractor's license number issued by the 37915
 Nevada driller's license number issued by the 1418
 Division of Water Resources, the on-site driller
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 6-17-05

