

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55301

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Jim Stockman ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 10260 Placerville Rd.  
Reno, NV 89506  
 2. LOCATION SW 1/4 NW 1/4 Sec. 13 T 21N N/S R 18E E Washoe County  
 PERMIT NO. 086-250-70 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown sandy clay		1	53	52
Soft zone		53	54	1
Brown sandy clay		54	60	6
Fine gray sand		60	61	1
Brown sandy clay		61	144	83
Soft zone		144	146	2
Brown sandy clay		146	160	14
Soft zone		160	168	8
Brown sandy clays		168	227	59
Soft zone	x	227	234	7
Brown sandy clays		234	251	17
Soft zone	x	251	264	13
Brown sandy clay		264	275	11

Washoe County Well Permit # WL 050109

8. WELL CONSTRUCTION  
 Depth Drilled 275 Feet Depth Cased 275 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 50 Feet  
10 5/8 Inches 8 5/8 Inches  
 From 50 Feet To 275 Feet  
8 5/8 Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	275

Perforations:  
 Type perforation Machine cut  
 Size perforation 3/32 x 3  
 From 229 feet to 269 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 275 feet

9. WATER LEVEL  
 Static water level 155 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 6/13/2005

Date started 6/9/2005, 19\_\_\_\_  
 Date completed 6/13/2005, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>3</u>

RECEIVED  
 05 JUN 23 AM 11:31  
 STATE ENGINEERS OFFICE