WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97059
Permit No.
Basin 103

NOTICE OF INTENT NO. 55790

1. OWNER Tom Redican
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3260 Six mile canyon (3260)

2. LOCATION W ¼ NW ¼ Sec 25 T 17 N/S R 21 E Storey County
PERMIT NO. ~~7209~~ Issued by Water Resources | 4-321-39 Parcel No. | Mucktwain Estates Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Yellow Clay | | 0 | 60 | |
| Soft Blue Rock | | 60 | 120 | |

RECEIVED
05 JUN 23 AM 11:17
STATE ENGINEERS OFFICE

Date started 6-10-05, 20
Date complated 6-10-05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20+ | 80 Ft | 2 Hrs |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| 10 5/8 Inches | 0 Feet | 50 Feet |
| 8 3/4 Inches | 50 Feet | 120 Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | 188 | +1 | 20 |
| 6 5/8 | | SDR 21 | 20 | 120 |

Perforations:
Type perforation saw cut
Size perforation 5/16
From 80 feet to 100 feet
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal ~~80~~ 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 120 feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 60 °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address BX 549 Silver Springs Contractor

Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-10-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627