

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 97074  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54909

1. OWNER TOM MADOLE  
 MAILING ADDRESS 18 AIRPORT ROAD  
FALLON, NV 89406  
 ADDRESS AT WELL LOCATION 18 AIRPORT ROAD

2. LOCATION NE 1/4 NW 1/4 Sec 30 T 19 N R 29 E CHURCHILL County  
 PERMIT NO. 007-691-02  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	15	15
BROWN CLAY		15	20	5
BROWN SAND		20	30	10
GREY SAND-CLAY		30	80	50
BROWN SAND-SILT		80	95	15
BROWN SILT-CLAY		95	120	25
GRAY SANDS-CLAY		120	200	80
GREEN SILTY SAND		200	208	8
BASALT	<i>X</i>	208	220	12

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/4 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>220</u>

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080  
 From 212 feet to 216 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 38' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

Date started MAY 24, 20 05  
 Date completed MAY 25, 20 05

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>30 +</u>			<u>1 HR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WELSCO CORP. (CONTRACTOR)  
 Address P. O. BOX 888 (CONTRACTOR)  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199  
 Signed WCB  
 By driller performing actual drilling on site or contractor  
 Date MAY 27, 2005

RECEIVED  
 05 JUN 10 AM 11:57  
 STATE ENGINEERS OFFICE