

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA

OFFICE USE ONLY

DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

Log No. 97075
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53107
7250 ANNETTE

1. OWNER CASEY PROPERTIES
 MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406
 ADDRESS AT WELL LOCATION FALLON, NV 89406

2. LOCATION NW 1/4 SE 1/4 Sec 1 T 19 N R 27 E CHURCHILL County
 PERMIT NO. 007-122-11
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	20	19
BROWN CLAY		20	30	10
BROWN SANDS		30	35	5
GRAY SANDS/CLAY		35	60	25
BLACK SILT/CLAY		60	80	20
GRAY SANDS/CLAY		80	180	100
BROWN CLAY		180	185	5
BROWN CLAY/SANDS		185	190	5
BROWN SANDS	X	190	201	11

8. WELL CONSTRUCTION
 Depth Drilled 201 Feet Depth Cased 201 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 50 Feet
6 Inches 50 Feet 201 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>201</u>

Perforations:
 Type perforation MACHINE PERF
 Size perforation .080
 From 193 feet to 197 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 22'3" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO CORP.
 (CONTRACTOR)

Date started MARCH 10, 20 05
 Date completed MAY 15, 20 05

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>30</u>			<u>1 HR</u>

Address P. O. BOX 888
 (CONTRACTOR)
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date JUNE 7, 2005

RECEIVED
 05 JUN 10 AM 11:57
 STATE ENGINEERS OFFICE