COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97086
Permit No.
Basin 101
NOTICE OF INTENT NO. 54908

1. OWNER THE WOODWORM
MAILING ADDRESS 620 RICE ROAD
FALLON, NV 89406
ADDRESS AT WELL LOCATION 2238 LONGHORN
FALLON, NV 89406

2. LOCATION NE ¼ NW ¼ Sec 11 T 18 N R 28 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) | 006-351-40 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	15	5
BROWN SAND/CLAY		15	40	25
GRAY SANDS		40	60	20
BLACK SILT/CLAY		60	80	20
GRAY SANDS		80	95	15
GRAY CLAY		95	98	3
BROWN SANDS/GRAVELS		98	114	16

RECEIVED 05 JUN 10 AM11:58 STATE ENGINEERS OFFICE

Date started MAY 26, 20 05
Date completed MAY 26, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION

Depth Drilled 114 Feet Depth Cased 114 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
103/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	114 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	114

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 108 feet to 112 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 19'3" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date JUNE 8, 2005

Forms Provided by Forms-On-A-Disk, Inc. - (214) 340-9429 - FormsOnADisk.com