

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 97089
 Permit No. _____
 Basin 105
 NOTICE OF INTENT NO. 52307

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MIKE HICKEY CONSTRUCTION ADDRESS AT WELL LOCATION 1061 WATERLOO LN
 MAILING ADDRESS 1700 COUNTY RD A GARDNERVILLE, NV 89410
MINDEN, NV 89423

2. LOCATION NW 1/4 NW 1/4 Sec 8 T 12 N R 20 E DOUGLAS County

PERMIT NO. 1220-08-001-022
 Issued by Water Resources _____ Percol No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAY		0	5	5
COURSE SANDS AND GRAVELS		5	13	8
COURSE GRAVELS		13	38	25
LARGE GRAVELS		38	93	55
SMALL LAYER CLAY		93	108	15
SMALL GRAVELS		108	121	13
FRACTURED GRAVELS SAND SANDS	X	121	160	39
COURSE LARGE GRAVELS	XXX	160	180	20

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 3/4 Inches _____ 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	180

Perforations:
 Type perforation SAW CUT
 Size perforation 3 X 3/32
 From 140 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level _____ 15 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 4/21, 20 05
 Date completed 4/22, 20 05

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
Draw Down (Feet Below Static)			
Time (Hours)			
<u>25+</u>		<u>35</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 0055548
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/26/05

RECEIVED
 -05 JUN 10 AM 10:19
 STATE ENGINEERS OFFICE