COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97091
Permit No.
Basin 071

NOTICE OF INTENT NO. 55663

1. OWNER John & Pam Schmoyer
MAILING ADDRESS 22088 Reading Drive
Anderson, CA 96007

ADDRESS AT WELL LOCATION 4900 Kathey Way
Winnemucca, NV 89445

2. LOCATION Lot 2 ¼ Block A ¼ Sec 30 of Tycana T 35 N R 38 E Humboldt County

PERMIT NO. (Issued by Water Resources) | 010-645-02 (Parcel No.) | Tycana (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobles		0	5	5
Sand & Gravel		5	30	25
Cobles & Gravel		30	90	70
Hard rock		90	95	5
Cobles		95	110	15
Sand course gravel		110	150	40
clay		150	195	45
Cobles		195	200	5
Clay and sand		200	275	75
Clay		275	300	25
Cobles		300	310	10
Clay		310	320	10
Sand & find gravel		320	350	30
Clay		350	360	10

Date started May 10, 20 05
Date completed May 27, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		8

8. WELL CONSTRUCTION

Depth Drilled 360 Feet Depth Cased 358 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	360 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	39
6.625	4.06	.316	39	360

Perforations:
Type perforation Factory cut
Size perforation 0.50
From 320 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 360 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 184' feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed [signature] By driller performing actual drilling on site or contractor
Date June 8, 2005

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com