

Log No. 97093
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49217

1. OWNER John Hillinbrand ADDRESS AT WELL LOCATION 2892 North 48th west st Ely NV 89301
 MAILING ADDRESS 2339 Moorpark way Henderson NV 89014
 2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 17 S. R. 63 E. White Pine County CROSS TIMBERS
 PERMIT NO. 005-571-65 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	6	6
Sand-Grauel-Boulders		6	80	74
Clay Grauel		80	90	10
Sand-Boulders	X	90	110	20
Hard Rock		110	135	25
gauel boulders-Clay	X	135	155	20
Hard Rock		155	160	5

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>		<u>5cl 40PVC</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation saw cut
 Size perforation 18" x 6"
 From 60 feet to 80 feet
 From 120 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50' feet to 160 feet

RECEIVED
 05 JUN 13 PM 1:00
 STATE ENGINEERS OFFICE

Date started 5-17-05, 19_____
 Date completed 5-20-05, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>45</u>		<u>3</u>

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling and Pumps Contractor
 Address HC 61 Box 54 Hiko NV 89017 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 5-27-05