COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97095
Permit No.
Basin 105

NOTICE OF INTENT NO. 52316

1. OWNER DENNIS CLARK
MAILING ADDRESS P.O. BOX 909
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 2731 KAYNE
MINDEN, NV 89423

2. LOCATION NW ¼ SE ¼ Sec 34 T 14 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1420-34-201-016 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BLOW SANDS | | 0 | 3 | 3 |
| COURSE SANDS | | 3 | 9 | 6 |
| BROWN CLAY | | 9 | 63 | 54 |
| SMALL SILTY SANDS | | 63 | 132 | 69 |
| BROWN CLAY | | 132 | 146 | 14 |
| COURSE DG SANDS | | 146 | 180 | 34 |

Date started 5/28, 20 05
Date completed 529, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 35 | 3 HRS |

8. WELL CONSTRUCTION

Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 3/4 Inches | 0 Feet | 180 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | +2 | 20 |
| 6 5/8 sdr21 | 4.06 | .216 | 20 | 180 |

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 60 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 180 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 00055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6/6/05