

Log No. 97109  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53460

1. OWNER SANTONI, DEU. ADDRESS AT WELL LOCATION 139 TAYLOR CREEK  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 SE 1/4 Sec. 4 T. 12 N/S R. 19 E Douglas County  
 PERMIT NO. 1279-04-001.034 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DG</u>		<u>0</u>	<u>14</u>	<u>14</u>
<u>DG &amp; BROWNISH CLAY</u>		<u>14</u>	<u>26</u>	<u>12</u>
<u>GRANITE BULDERS</u>	<input checked="" type="checkbox"/>	<u>26</u>	<u>61</u>	<u>35</u>
<u>BROWNISH WHITE CLAY</u>	<input checked="" type="checkbox"/>	<u>61</u>	<u>106</u>	<u>45</u>
<u>DG &amp; CLAY</u>	<input checked="" type="checkbox"/>	<u>106</u>	<u>162</u>	<u>56</u>
<u>DG</u>	<input checked="" type="checkbox"/>	<u>162</u>	<u>200</u>	<u>38</u>

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>14</u>	<u>1.88</u>	<u>H</u>	<u>20</u>
<u>65/8</u>	<u>4</u>	<u>SDR21</u>	<u>20</u>	<u>200</u>

Perforations:  
 Type perforation GRINDER CUT  
 Size perforation 1.045" x 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 104 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 104 feet to 200 feet

9. WATER LEVEL  
 Static water level 46 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC.  
 Address P.O. Box 1255 Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Watson  
 By driller performing actual drilling on site or contractor  
 Date 4-9-05

Date started Apr 8, 2005  
 Date completed Apr 9, 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>18-20</u>		<u>1.0</u>