

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 97113  
 Permit No. 167  
 Basin 167  
 NOTICE OF INTENT NO. 53463

1. OWNER Linda & Gilbert Cook ADDRESS AT WELL LOCATION 133 ARTIST VIEW  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 SW 1/4 Sec 18 T. 24 N. R. 24 E. Lyon County Clark  
 PERMIT NO. 010-411-15 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	18	18
BR CLAY-GRAVEL		18	68	50
GRAVEL	X	68	90	22
BLACK SAND		90	146	56
BLACK CLAY-SAND	X	146	205	59
BR SAND-GRAVEL	X	205	240	35

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>20</u>	<u>240</u>

Perforations:  
 Type perforation GRINDER CUT  
 Size perforation .045" X 4"  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 52 ft  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 52 feet to 240 feet

9. WATER LEVEL  
 Static water level 91 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

Date started MAR 11 2005  
 Date completed MAR 18 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20-22</u>		<u>2.0</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BLAIN DRILLING & PUMP CO. INC.  
 Address P.O. Box 1255 Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Detton  
 By driller performing actual drilling on site or contractor  
 Date 3-18-05

RECEIVED  
 05 APR 11 PM 11:13  
 STATE ENGINEERS OFFICE