WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

97163
OFFICE USE ONLY
Log No.
Permit No.
Basin 105

NOTICE OF INTENT NO. 55295

1. OWNER Bill Garrison
MAILING ADDRESS P.O. Box 43
Genoa, NV 89411

ADDRESS AT WELL LOCATION 941 Airport Rd Minden
NV.

2. LOCATION SW 1/4 SE 1/4 Sec. 07 T 13N N/S R 20E E Douglas County
PERMIT NO. 70132 Issued by Water Resources
1320-07-002-008 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	5	5
Sand & gravel		5	50	45
Clay		50	65	15
Sand & gravel		65	80	15
Brown clay		85	90	5
Sand small gravel		90	110	20
Brown clay		110	115	5
Sand	x	115	120	5
Coarse sand small gravel	x	120	180	60

Date started 5/13/2005, 19__
Date completed 5/17/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200+		3

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17.5	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	180

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 120 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 5/19/2005

USE ADDITIONAL SHEETS IF NECESSARY