WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

97188
OFFICE USE ONLY
Log No.
Permit No.
Basin 050

NOTICE OF INTENT NO. 54614

1. OWNER TONY CARTER
MAILING ADDRESS 875 HILLSIDE DRIVE
ELKO, NV 89801

ADDRESS AT WELL LOCATION WEST OFF OF CATTLE DRIVE

2. LOCATION SE 1/4 NE 1/4 Sec. 7 T 34N N/S R 55E E ELKO County
PERMIT NO. Issued by Water Resources
006-098-064 Parcel No.
SPECIAL LANDS Subdivision Name

3. WORK PERFORMED
X New Well, Replace, Recondition, Deepen, Abandon, Other

4. PROPOSED USE
[X] Domestic, [ ] Irrigation, [ ] Test, [ ] Municipal/Industrial, [ ] Monitor, [ ] Stock

5. WELL TYPE
[ ] Cable, X Rotary, RVC, X Air, Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BROWN SILTSTONE		2	65	63
RED VOLCANIC		65	85	20
BROWN SILTSTONE		85		
W/GRAVEL			160	75
BROWN SILTSTONE, FIRM		160	240	80
MEDIUM GREY SILTSTONE		240	390	150
GREY SILTSTONE, HARD		390	480	90
BROWN SILTSTONE	510	480		
W/GRAVEL			540	60

Date started 2/1/2005, 19__
Date completed 2/4/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60+		3 HRS

8. WELL CONSTRUCTION
Depth Drilled 540 Feet Depth Cased 540 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	540	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1	540

Perforations:
Type perforation MACHINED MILL SLOT
Size perforation 3/16 X 3 INCHES, 6 ROW
From 500 feet to 540 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 540 feet

9. WATER LEVEL
Static water level 272 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC Contractor
Address P.O.BOX 850 Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed Bradley A. Wiesl
By driller performing actual drilling on-site or contractor
Date 2/8/2005

USE ADDITIONAL SHEETS IF NECESSARY