WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97230
Permit No.
Basin 87

NOTICE OF INTENT NO. 49551

1. OWNER Airport Authority of Washoe County
MAILING ADDRESS P.O. Box 12940
Reno, NV 89502

ADDRESS AT WELL LOCATION In the area of Home Gardens Drive, Tyrone Way and Marvel Way in SE Reno

2. LOCATION NE 1/4 NE 1/4 Sec. 31 T 19N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) 025,385,386, 387-01 (Parcel No.) Home Gardens (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Well #67 | | | | |
| Measured static water level at 8.4'. Depth of well | | | | |
| was 38'. Installed pipe and blew debris from well | | | | |
| to a depth of 53' where we hit hard bottom. Well | | | | |
| had a 5" thin wall liner set in it that was | | | | |
| deterioated. The 6" casing also had holes in it. | | | | |
| We then installed 50' of tremme pipe, mixed 11 | | | | |
| bags of cement with 60 gallons of water and pumped | | | | |
| seal in from bottom of well to surface. Casing was | | | | |
| cut off 5' below ground surface. | | | | |

Date started 5/25/2005, 19__
Date completed 6/2/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 53' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| ____ Inches | ____ Feet | ____ Feet |
| ____ Inches | ____ Feet | ____ Feet |
| ____ Inches | ____ Feet | ____ Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6" | | .188 | +1 | 53' |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 8.4' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6/16/2005

USE ADDITIONAL SHEETS IF NECESSARY