WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97236
Permit No.
Basin 105

NOTICE OF INTENT NO. 51806

1. OWNER DA Development Co Inc
MAILING ADDRESS 1329 Hwy 393 Ste 10-111 Gardnerville NV 89410
ADDRESS AT WELL LOCATION 1232 Golden Eaglect Gardnerville NV

2. LOCATION NW ¼ SW ¼ Sec. 01 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. — (Issued by Water Resources) 122001002039 (Parcel No.) Sterling Ranch (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND gravel COBBLES		0	30	30
CLAY		30	45	15
SAND GRAVEL COBBLES		45	103	58
CLAY		103	120	17
SAND gravel COBBLES	X	120	145	25
CLAY		145	171	26
SANDY gravel		171	174	3
CLAY		174	180	6
SANDY gravel		180	186	6
CLAY		186	193	13
SANDY gravel		193	196	3
CLAY		196	202	6
SANDY gravel		202	222	20

Date started 4-2-05, 19
Date completed 4-22-05, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+-		4+

8. WELL CONSTRUCTION
Depth Drilled 222 Feet Depth Cased 222 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 222 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	180
			220	222

Perforations:
Type perforation factory slot
Size perforation 3/32 x 3"
From feet to feet
From feet to feet
From 180 feet to 220 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 222 feet

9. WATER LEVEL
Static water level 118 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COOL F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nevada Drilling + Pump LLC (Contractor)
Address 3540 Green Acre Dr (Contractor)
Carson City NV 89705
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1902
Signed John S Leisel (By driller performing actual drilling on site or contractor)
Date 4-21-05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627