


REPORT NO. A05.046

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT



LOG NO. 97248
PERMIT NO. _____
BASIN 83

NOTICE OF INTENT NO. 56266

1. OWNER Michael DePalma ADDRESS OF WELL 3010 Northstar Rd.
MAILING ADDRESS 4235 Primavera Ave. Reno, NV 89502 Virginia City Highlands, NV 89521
2. WELL LOCATION SW 1/4 NW 1/4 SEC. 27 T 18N R 21 E Storey COUNTY
PERMIT NO. _____ PARCEL NO. 3-351-20 SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Brown dirt, clay, volcanic rock		0	5	5
Dark green & blue volcanic rock		5	30	25
Red volcanic rock & red clay		30	35	5
Blue-green volcanic rock & clay		35	130	95
Multi-color volcanic rock & reddish brown sandy clay		130	170	40
Blue/green/orange clay		170	210	40
Dark blue basalt		210	220	10
Green volcanic rock w/ specs of red clay		220	230	10
Reddish brown hard dry clay & dark blue hard rock	X	230	245	15
Dark reddish brown volcanic rock & orange clay		245	318	73

Notes : **Latitude: N39 degrees 23.830'**
Longitude: W119 degrees 36.214'

Date Started 5/24/05 Date Completed 5/26/05

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

GPM	DRAWDOWN	TIME (HRS)
20+		1.5 hrs.

8. WELL CONSTRUCTION

Depth Drilled 318 Depth Cased 318
HOLE DIAMETER (BIT SIZE)
10 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 318 Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	318

PERFORATIONS:

Type Perforation Factory Size Perforation 3/32 x 3
From 278 Feet to 318 Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL:

Yes No SEAL TYPE:
Seal Depth 50 Neat Cement
 Cement Grout
PLACEMENT METHOD: Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED:

Yes No
From 50 Feet to 318 Feet

9. WATER LEVEL

Static Water Level 220 Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC NO. 15291 DRILLER'S LIC. NO. 2189
ON SITE

Signed [Signature]
By driller performing actual drilling on site or contractor
Dated May 26, 2005