COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. ~~969~~ 97270
Permit No.
Basin 812

NOTICE OF INTENT NO. 29387

1. OWNER BELLAGIO
MAILING ADDRESS PO BOX 7700
LAS VEGAS. NV 89177-0700

ADDRESS AT WELL LOCATION 3620 INDUSTRIAL RD.
LAS VEGAS, NV

2. LOCATION SE ¼ NE ¼ Sec 20 T 21 S R 61 E CLARK County

PERMIT NO. DW1199 (Issued by Water Resources) | 162-20-501-005 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2-Monitor wells				
Type II		0	2	2
Brown Silty dirt		2	6	4
Caliche		6	7	1
Brown clay		7	13	6
Tan silty clay & rock		13	17	4
White clay		17	23	6
Caliche		23	27	4
Brown silty clay		27	31	4
Tan clay		31	37	6
White clay & rock		37	45	8
Red clay		45	52	7
Tan clay		52	57	5
Brown slity clay		57	60	11

DCNR/DWR
RECEIVED
JUL 14 2005
LAS VEGAS OFFICE

Date started 6/25, 20 05
Date completed 6/25, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Machine
Size perforation 1/4" x 2.5"x21 per ft.
From 60 feet to 10 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal _____ ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 60' feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow _____ G.P.M _____ P.S.I
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161
Signed _____
By driller performing actual drilling on site or contractor
Date 7/11/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com