WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No.
Permit No.
Basin

1. OWNER MARK WILLIAMS ADDRESS
ELKO, NEV.

2. LOCATION NW ¼ NW ¼ Sec. 15 T. 33 N/S R. 55 E. ELKO County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL	NO	0	1	1
CLECHE HARDPAN	NO	1	155	154
CLAY + SAND	NO	155	220	65
GRAVEL + SAND	YES	220	230	10
CLECHE HARDPAN	NO	230	270	40
GRAVEL + SAND	YES	270	300	30

RECEIVED
OCT 25 1982
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 8/12, 1982
Date completed 8/14, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 300 feet
Casing record 6" x .156
Weight per foot Thickness .156

Diameter	From	To
6 inches	+1 feet	-300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT GROUT
Depth of seal 50 FT. feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation SLOT
Size perforation 1/8 x 36"
From 300 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 130 Feet below land surface 129
Flow NO G.P.M. 0
Water temperature GOOD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GARY C SORENSEN
Address RT 2 Box 706
Nevada contractor's license number 015356
Nevada driller's license number 1299
Signed Gary C Sorensen
Date 8/14/82

USE ADDITIONAL SHEETS IF NECESSARY

O-627