

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **97346**
 Permit No. _____
 Basin **162**
 NOTICE OF INTENT NO. **28234**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Janser Estrella**
 MAILING ADDRESS **3431 S. Tournament Pahrump, NV 89060**
 ADDRESS AT WELL LOCATION **3431 S. Tournament**

2. LOCATION **SW 1/4 SW 1/4 Sec. 34 T 20S N/S R 53E E Nye** County
 PERMIT NO. **40-662-03** Parcel No. _____ Subdivision Name **Calvada Valley**

Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay	x	0	108	108
brown caleche	x	108	112	4
See next line	x	112	127	15
brown clay with caleche strings				
brown clay	x	127	166	39
brown caleche	x	166	170	4
brown clay	x	170	174	4
brown caleche	x	174	192	18
See next line	x	192	200	8
brown clay with caleche strings				

DCNR/DWR
RECEIVED
AUG 10 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled **200** Feet Depth Cased **200+1** Feet

HOLE DIAMETER (BIT SIZE)
 From **11** Inches To **0** Feet **200** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**
 From **160** feet to **200** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **200** feet

9. WATER LEVEL
 Static water level **72** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **5801 S. Homestead** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed _____
 By driller performing actual drilling on-site or contractor
 Date **8.4.05**

Date started **7-24-05** 19____
 Date completed **7-24-05** 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)