

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28592

1. OWNER CHRISTINA HOLZER ADDRESS AT WELL LOCATION LAVA AV. & PIMA ST. SANDY VALLEY NV
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NW 1/4 Sec. 26 T. 24 N. OR 56 E. CLARK County _____
 PERMIT NO. 200-26-101-021 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	3	3
CLAY		3	32	29
CALICHE		32	36	4
CLAY		36	58	22
CALICHE		58	64	6
CLAY		64	73	9
CALICHE	W.B	73	76	3
CLAY		76	88	12
CALICHE	W.B	88	92	4
CLAY		92	105	13
CALICHE	W.B	105	112	7
CLAY		112	132	20
CALICHE	W.B	132	138	6
CLAY		138	140	2

DCNR/DWR
 RECEIVED
 AUG 15 2005
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 8 INCH BY 6 INCH
 From 140 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Budget Drilling Co Contractor
 Address P.O. Box 3505 Contractor
Patrum NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Amie Ban
 By driller performing actual drilling on site or contractor
 Date 8-2-05

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			