

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **97415**  
 Permit No. **69196**  
 Basin **162**

NOTICE OF INTENT NO. **28984**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **MOUNTAIN FALLS GOLF COURSE** ADDRESS AT WELL LOCATION **4750 MT FALLS PARKWAY**  
 MAILING ADDRESS **4750 MT FALLS PARKWAY**  
**PAHRUMP, NV**

2. LOCATION **NE 1/4 SE 1/4 Sec. 5 T 21S N/S R 54E E NYE** County  
 PERMIT NO. **69196** Issued by Water Resources Parcel No. **45-021-26** Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	65	65
CALICHE	WB	65	66	1
CLAY		66	126	60
CALICHE	WB	126	131	5
CLAY		131	165	34
GRAVEL	WB	165	174	9
CLAY		174	225	51
GRAVEL	WB	225	234	9
CLAY		234	268	34
LIMESTONE	WB	268	283	15
GRAVEL	WB	283	304	21
CLAY		304	356	52
CEMENTED GRAVEL & SAND		356	386	30
GRAVEL & CLAY		386	410	24
GRAVEL		410	420	10

DCNR/DWR  
 RECEIVED  
 AUG 29 2005  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled **420** Feet Depth Cased **420** Feet

HOLE DIAMETER (BIT SIZE)  
 From **12.25** Inches To **0** Feet **420** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	420

Perforations:  
 Type perforation **FACTORY SAWCUT**  
 Size perforation **1/8 X 3**

From **100** feet to **420** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal **50**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **420** feet

9. WATER LEVEL  
 Static water level **62** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **P.O. BOX 4220** Contractor  
**PAHRUMP, NV. 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**  
 Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **8/16/2005**

Date started **8/19/2005** 19  
 Date completed **8/15/2005** 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			