


Well Log DB indicates 12 in, but should be 8 inch! Thanks, Bobby D.

WHITE - DIVISION OF WATER RESOURCES  
 CANARY - CLIENT'S COPY  
 PINK - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 97441  
 Permit No. 72109  
 Basin 162  
  
 NOTICE OF INTENT NO. 29016

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MURPHY FAMILY TRUST ADDRESS AT WELL LOCATION 121 E IRENE ST  
 MAILING ADDRESS 121 E IRENE ST  
PAHRUMP, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 10 T 20S N/S R 53E E NYE County  
 PERMIT NO. 72109 35-111-22 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	68	68
CLAY		68	106	38
CLAY & GRAVEL		106	120	14
GRAVEL	WB	120	131	11
CLAY & GRAVEL		131	196	65
GRAVEL	WB	196	214	18
CLAY & GRAVEL		214	246	32
GRAVEL	WB	246	263	17
CLAY		263	289	26
CALICHE	WB	289	294	5
CLAY		294	334	40
CALICHE	WB	334	356	22
CLAY		356	370	14
GRAVEL	WB	370	460	90

DCNR/DWR  
 RECEIVED  
 OCT 12 2005  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 20 Feet  
14.5 Inches 0 Feet 20 Feet  
12.25 Inches 20 Feet 460 Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	24.20	.180	02	20
8	16.94	.188	20	460

Perforations:  
 Type perforation FACTORY SAWCUT  
 Size perforation 1/4 X 3

From	120	feet to	160	feet
From	240	feet to	260	feet
From	280	feet to	300	feet
From	320	feet to	340	feet
From	360	feet to	460	feet

Surface Seal:  Yes  No  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 460 feet

9. WATER LEVEL  
 Static water level 82 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor  
 Address P.O. BOX 4220 Contractor  
PAHRUMP, NV. 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas D...  
 By driller performing actual drilling on-site or contractor  
 Date 9/28/2005

Date started 9/27/2005 .19  
 Date completed 9/27/2005 .19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	
	G.P.M.	Draw Down (Feet Below Static) Time (Hours)

USE ADDITIONAL SHEETS IF NECESSARY