COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97479
Permit No.
Basin 212

NOTICE OF INTENT NO. 29396

1. OWNER CLARK COUNTY SANITATION
MAILING ADDRESS 5857 E FLAMINGO RD.
LAS VEGAS, NV 89122

ADDRESS AT WELL LOCATION 5857 E FLAMINGO RD.
LAS VEGAS, NV 89122 (S. SECONDARY FACILITIES)

2. LOCATION NE ¼ NW ¼ Sec 22 T 21 S R 62 E CLARK County

PERMIT NO. R1291 (Issued by Water Resources) | 161-22-101-001 (Parcel No.) | CLARK (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Plug 4 Dewater wells				
Depth 40'				
All excavated down to 20'				
and recompacted back up				
to 8-10'.				
Extract well #1 and filled				
with 9 sack cement grout.				
Well#2 casing broke at 10'				
Well#3 & 4 broke at 20'				
Casing were abandon in				
place and pressure grout				
through a trimmie from				
the bottom to the surface				
8 yards of 23 sack cement				
slurry total.				

DCNR/DWR
RECEIVED
OCT 3 - 2005
LAS VEGAS OFFICE

Date started 9/7, 20 05
Date completed 9/8, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
Signed Fred B. Allen III
By driller performing actual drilling on site or contractor
Date 9/27/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com