WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97493
Permit No.
Basin 162

NOTICE OF INTENT NO. 28941

1. OWNER Johnson Construction
MAILING ADDRESS 2861 E. Deerskin
Pahrump, NV 89060

ADDRESS AT WELL LOCATION
2861 E. Deerskin

2. LOCATION NE 1/4 SE 1/4 Sec. 36 T 20S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources
41-063-12 Parcel No.
Calvada Valley Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| brown silty loam | | 0 | 28 | 28 |
| See next line | | 28 | 36 | 8 |
| brown silty loam with caleche strings | | | | |
| brown clay | | 36 | 69 | 33 |
| brown caleche | | 69 | 78 | 9 |
| See next line | x | 78 | 200 | 122 |
| brown loam with caleche strings | | | | |

DCNR/DWR
RECEIVED
SEP 28 2005
LAS VEGAS OFFICE

Date started 9/10/~~1905~~ 2005 DBB, 19__
Date completed 9/10/~~1905~~ 2005, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**
Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 11 | Inches | 0 | Feet | 200 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

Perforations:
Type perforation sawcut
Size perforation .188
From 160 feet to 200 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

**9. WATER LEVEL**
Static water level 78 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor
Address 5801 S. Homestead
Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 9-21-05