

97505

OFFICE USE ONLY

Log No. 32442
 Permit No. _____
 Basin 87

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12901

1. OWNER Curry Corp ADDRESS AT WELL LOCATION 1700 E Plum
 MAILING ADDRESS 2741 W 29 AV LANE Reno NV
Hollywood Fl 33020
 2. LOCATION NW 1/4 NE 1/4 Sec 19 T 19 N R 20 E Washoe County
 PERMIT NO. m/0190 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Hollow stem

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	3'	3'
Brown clayey sand no gravel		3'	6'	5.9
Brown to grey sand poorly graded no gravel		6'	12'	6'
grey sand w/ gravel		12'	18'	6'
Black silty clayey sand		18'	22'	

8. WELL CONSTRUCTION

Diameter 2" inches Total depth 22' feet

Casing record
 Weight per foot _____ Thickness _____

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal surface 10' feet
 Gravel packed: Yes No
 Gravel packed from 10' feet to 22' feet

Perforations:
 Type perforation PVC screen
 Size perforation .015
 From 12' feet to 22' feet

9. WATER LEVEL

Static water level 214 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. D. Anderson
 Address 1635 Belvedere Reno NV, 89509
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed W. D. Anderson
 Date 10/3/89

Date started 9/22 1987
 Date completed 9/22 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1100</u>	<u>11.00</u>	<u>08'</u>	

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours