

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 97514  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **29106**

1. OWNER **BRIAN GRAHAM** ADDRESS AT WELL LOCATION **1671 W GEOFREY ST**  
 MAILING ADDRESS **1671 W GEOFREY ST**  
**PAHRUMP, NV**

2. LOCATION NE 1/4 NW 1/4 Sec. 32 T 19S N/S R 53E E NYE County  
 PERMIT NO. 41-583-06 GOLDEN SPRING RANCH UNIT 7  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	8	8
CALICHE		8	14	6
CLAY		14	38	24
CALICHE		38	50	12
CLAY		50	67	17
CALICHE	WB	67	84	17
CLAY		84	105	21
CALICHE	WB	105	128	23
CLAY		128	152	24
CALICHE	WB	152	178	26
CLAY		178	190	12
CALICHE	WB	190	200	10

DCNR/DWR RECEIVED  
 OCT 31 2005  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 200 Feet  
 From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:  
 Type perforation **SAWCUT**  
 Size perforation 1/8 X 3  
 From 100 feet to 120 feet  
 From 140 feet to 160 feet  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **P.O. BOX 4220** Contractor  
**PAHRUMP, NV. 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1478**  
 Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **10/25/2005**

Date started 10/21/2005, 19  
 Date completed 10/21/2005, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			