

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 27886

1. OWNER R + S Alexander LLC ADDRESS AT WELL LOCATION NA
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SE 1/4 Sec 34 T 19 S N/S R 61 E Clark County
 PERMIT NO. 124-34-701-028 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
8" Well		300 FT	Deep	
No Pump				
No Debris				
PERFORATE FROM 300 FT UP				
AIR OPERATED PERFORATOR 1 1/2" X 3/4" FOR 2 TIMES PERIOD				
TO 50 FT. CEMENT SEAL				
PUMP 6 yds neat cement				
FROM BOTTOM UP TO 20 FT				
20 ft up with 5 sack mix				
STATIC WATER 79 ft.				

DCNR/DWR
 RECEIVED
 SEP 26 2005
 LAS VEGAS OFFICE
 PLUGGING OF
 LOG # 41990

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From _____	To _____	_____
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____
 Size perforation _____

From	feet to	feet
From _____	_____	_____

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 09-13-05, 20 ____
 Date completed 09-15-05, 20 ____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level 79 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VERNON H. DIMICK Contractor
 Address 5360 N. BONITA VISTA ST.
LV NV 89149 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V H Dimick
 By driller performing actual drilling on site or contractor
 Date 09-26-05