COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97575
Permit No.
Basin 212

NOTICE OF INTENT NO. 29451

1. OWNER RUFFIN GAMING LLC
MAILING ADDRESS 3120 LAS VEGAS BLVD. S
LAS VEGAS, NV 89109-1966

ADDRESS AT WELL LOCATION 3120 S. LAS VEGAS BLVD.
LAS VEGAS, NV

2. LOCATION NW ¼ NW ¼ Sec 16 T 21 S R 61 E CLARK County

PERMIT NO. DW1200 (Issued by Water Resources) | 162-16-101-005 & 007 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE Dewater-DSD
☐ Domestic ☒ ~~Irrigation~~ ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
8-Dewatering wells				
Asphalt		0'	3"	3"
Brown dirt		3"	8'	7'-9"
Caliche		8'	14'	6'
Brown silt	xx	14'	17'	3'
Brown silty clay		17'	21'	4'
White clay		21'	26'	6'
Red clay		26'	28'	2'
Brown clay		28'	34'	6'
White silty clay		34'	40'	7'

DCNR/DWR
RECEIVED
SEP 15 2005
LAS VEGAS OFFICE

Date started 8/11, 20 05
Date completed 8/15, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 40' Feet Depth Cased 40' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24" Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Machine
Size perforation .25"x2.5x3 rows @13
From 0 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred R. Allen III
By driller performing actual drilling on site or contractor
Date 9/8/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-8429 · FormsOnADisk.com