

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 97647
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29119

1. OWNER MIGUEL RAMOS
 MAILING ADDRESS 4660 E ASHLEY PAHRUMP, NV
 ADDRESS AT WELL LOCATION 4660 E ASHLEY

2. LOCATION NW 1/4 NW 1/4 Sec. 29 T 21S N/S R 54E E NYE County
 PERMIT NO. 45-331-16 GREEN SADDLE RANCH
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	110	110
CALICHE	WB	110	148	38
CLAY		148	156	8
CALICHE	WB	156	210	54
CLAY		210	220	10
DCNR/DWR RECEIVED				
OCT 31 2005				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 240 Feet
10.25 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	240

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From <u>120</u> feet to <u>140</u> feet
From <u>160</u> feet to <u>180</u> feet
From <u>200</u> feet to <u>240</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D...
 By driller performing actual drilling on-site or contractor
 Date 10/28/2005

Date started 10/27/2005 19
 Date completed 10/27/2005 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			