

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25577

1. OWNER Ralph Keys ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 S 1/4 Sec. 5 T. 4 N. R. 36 E. Bonanza County \_\_\_\_\_  
 PERMIT NO. 07-671-26 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Clay		1	6	
Sand Gravel		6	22	
Clay Sand		22	27	
Gravel		27	73	
Clay		73	92	
Sand Gravel		92	110	
Clay		110	140	
Gravel Sand		140	157	
Clay		157	178	
Clay Gravel		178	181	
Clay		181	200	

DCNR/DWR  
 RECEIVED  
 OCT 26 2005  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 1 Feet 50 Feet  
8 3/4 Inches 50 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.86</u>	<u>1</u>	<u>20</u>
<u>6 5/8</u>	<u>PVC</u>	<u>SORA</u>	<u>20</u>	<u>200</u>

Perforations:  
 Type perforation Machine Pore  
 Size perforation 3/16" low 6# Pore  
 From 1.25 feet to 1.55 feet  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50'  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 20' feet to 200' feet

9. WATER LEVEL  
 Static water level 88 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jan Driller Contractor  
 Address P.O. 898 Contractor  
88 N. 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9/18/05

Date started 9/17/05, 20  
 Date completed 9/17/05, 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10</u>		<u>3 1/2 hrs</u>