

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 28254

1. OWNER Lee Brookshire ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1960 Renssen CT Las Vegas NV 89117 _____
 2. LOCATION NE 1/4 SE 1/4 Sec. 23 T. 19 N. R. 60 E Clark County _____
 PERMIT NO. 125-23-302-021 Parcel No. N/A Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cedar Wood with Pine		67	76	9'
Steel Fence post		76	85	9'
unknown Auto parts wood		85	200	115'
clean hole		200	351	151'
Gravel, F. m Sand		351	386	35'
Description in old well is that the old well log says Cased From 0-200 8" casing From 200-450 10" casing				
Encountered Virgin material at 351 ft Drilled Well to 386 ft was Original Well log in correct				

DCNR/DWR RECEIVED
 NOV 17 2005

8. WELL CONSTRUCTION
 Depth Drilled 386 Feet Depth Cased 386 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
9" Inches 0 Feet 386 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>Factory</u>		<u>0</u>	<u>386</u>

Perforations:
 Type perforation Factory
 Size perforation _____
 From 225 feet to 386 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 65' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started 11-04 2005
 Date completed 11-14 2005

9. WATER LEVEL
 Static water level 74' feet below land surface
 Artesian flow _____ G.P.M. 35* P.S.I.
 Water temperature 60.6 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name T.D.C. Water Well & Pump Service Contractor
 Address 2870 W. Pebble Pt Las Vegas NV 89123 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 59948
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1737-71
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/15/05