

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26890

1. OWNER SCOTT GORDEN ADDRESS AT WELL LOCATION 2301 W DONNER ST PAHRUMP NV.  
 MAILING ADDRESS 1920 W CHARLESTON PAHRUMP NV.

2. LOCATION SW 1/4 NE 1/4 Sec. 13 T. 20 N/S R. 52 E. NYE County  
 PERMIT NO. 4141310 GOLDEN SPRING RCH Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>BRN CLAY</u>		<u>0</u>	<u>8</u>	<u>8'</u>
<u>CALICHE</u>		<u>8</u>	<u>11</u>	<u>3'</u>
<u>CLAY + GRAVEL</u>		<u>11</u>	<u>20</u>	<u>9'</u>
<u>GRAY CLAY</u>		<u>20</u>	<u>45</u>	<u>25'</u>
<u>BRN CLAY</u>		<u>45</u>	<u>65</u>	<u>20'</u>
<u>BRN CLAY</u>	<u>X</u>	<u>65</u>	<u>160</u>	<u>95'</u>

DCNR/DWR  
RECEIVED  
OCT 17 2005  
LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>5/8</u>	<u>40</u>	<u>0</u> <u>160</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/2 x 6"  
 From 100 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

Date started 10-1, 2005  
 Date completed 10-7, 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>	<u>20</u>	<u>2 HRS</u>

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LARRY'S WATER WELL SERVICE Contractor  
 Address PO Box 3392 PAHRUMP NV. Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2301  
 Signed Dale W. [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-7-2005