

COPIES TO

- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 97718  
 Permit No. \_\_\_\_\_  
 Basin 210

NOTICE OF INTENT NO. 23559

PRINT OR TYPE ONLY

1. OWNER Vidler Water Comp. Inc. KPW-1 ADDRESS AT WELL LOCATION Kane Springs Valley  
 MAILING ADDRESS 704 W. Nye Suite 201 Page 1 of 3  
Carson City, NV. 89703

2. LOCATION NE 1/4 SW 1/4 Sec 6 T 11 S R 64 E Lincoln County

PERMIT NO. \_\_\_\_\_ ISSUED BY WATER RESOURCES \_\_\_\_\_ PARCEL NO. N/A SUBDIVISION NAME N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

8. WELL CONSTRUCTION

Material	Water Strata	From	To	Thickness
Alluvium		0	265	265
Dolostone		265	505	240
Dolostone & Limestone		505	595	90
Limestone & Clay		595	605	10
Dolostone		605	625	20
Dolostone & Clay		625	635	10
Dolostone		635	685	50
Dolostone & Clay		685	695	10
Dolostone		695	835	140
Dolostone & Clay		835	845	10
Dolostone		845	865	20
Quartzite		865	885	20
Dolostone & Limestone		885	945	60
Clay & Dolostone		945	955	10
Dolostone & Clay		955	1085	130
Dolostone, Limestone & Clay		1085	1385	300
Dolostone		1385	1415	30
Clay		1415	1425	10
Quartzite		1425	1445	20
Dolostone & Limestone		1445	1545	100
Dolostone		1545	2015	470

Depth Drilled 2017 Feet Depth Cased 2012 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
38 Inches \_\_\_\_\_ 0 Feet \_\_\_\_\_ 80 Feet  
26 Inches \_\_\_\_\_ 80 Feet \_\_\_\_\_ 2017 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>34</u>	<u>179.89</u>	<u>0.500</u>	<u>0</u>	<u>80</u>
<u>18.625</u>	<u>73.09</u>	<u>0.375</u>	<u>+2</u>	<u>1020</u>
<u>18.625</u>	<u>61.02</u>	<u>0.312</u>	<u>1020</u>	<u>1840</u>

Perforations:  
 Type perforation Louvered 18.625  
 Size perforation 0.090"  
 From 1020 feet to 1840 feet  
 From 1882 feet to 2002 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 302'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 302 feet to 2017 feet

DCNR/DWR RECEIVED

NOV 28 2005

LAS VEGAS OFFICE

Date started October 15, 20 05  
 Date completed November 14, 20 05

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)

9. WATER LEVEL  
 Static water level 992.7 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 120 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lang Exploratory Drilling (CONTRACTOR)  
 Address P.O. Box 5279 (CONTRACTOR)  
Elko, NV. 89802  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1366  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date November 15, 2005



