WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97737
Permit No.
Basin 162

NOTICE OF INTENT NO. 29129

1. OWNER GARY NALLEY
MAILING ADDRESS 1530 W AMARILLO AVE
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1530 W AMARILLO AVE

2. LOCATION NE 1/4 SW 1/4 Sec. 29 T 20S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) | 40-251-21 (Parcel No.) | CALVADA VALLEY UNIT 5 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| WAIVER # R-1300 | | | | |
| PUMP E-Z SEAL | | | | |
| BENTINITE FROM 140' TO | | | | |
| 25' PUMP NEAT CEMENT | | | | |
| FROM 25' TO SURFACE | | | | |

DCNR/DWR
RECEIVED
NOV 21 2005
LAS VEGAS OFFICE

Date started 11/9/2005, 19__
Date completed 11/9/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| EXISTING | Inches | Feet | Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | .250 | 0 | 140 |
| | | | | |

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 140
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed ____ (By driller performing actual drilling on-site or contractor)
Date 11/9/2005

USE ADDITIONAL SHEETS IF NECESSARY