


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 97741

Permit No. _____

Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **29112**

1. OWNER M.D.I.
 MAILING ADDRESS 3240 SIMKINS
PAHRUMP, NV

ADDRESS AT WELL LOCATION 3240 SIMKINS

2. LOCATION SW 1/4 SE 1/4 Sec. 24 T 19S
 PERMIT NO. 27+731-75

N/S R 52E E NYE County

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	64	64
CALICHE	WB	64	68	4
CLAY		68	102	34
CALICHE	WB	102	114	12
CLAY		114	138	24
CALICHE	WB	138	146	8
CLAY		146	169	23
CALICHE	WB	169	178	9
CLAY		178	180	2

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

10.25 Inches From 0 Feet To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>180</u>

Perforations:

Type perforation SAWCUT

Size perforation 1/8 X 3

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No

Seal Type:

Depth of Seal 50

Neat Cement

Placement Method: Pumped

Cement Grout

Poured

Concrete Grout

Gravel Packed: Yes No

From 50 feet to 180 feet

9. WATER LEVEL

Static water level 62 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.

Contractor

Address P.O. BOX 4220

Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 11/23/2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M. Draw Down (Feet Below Static) Time (Hours)

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started 11/22/2005, 19
 Date completed 11/22/2005, 19

DCNR/DWR
 RECEIVED

DEC 1 - 2005

LAS VEGAS OFFICE