

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 97777  
 Permit No. \_\_\_\_\_  
 Basin 73A

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52509

1. OWNER Al Baker ADDRESS AT WELL LOCATION Old Victory Highway  
 MAILING ADDRESS 15 Mac Street Lovelock, NV  
Reno, NV 89436

2. LOCATION SW 1/4 SW 1/4 Sec 15 T 29 N R 33 E Pershing County  
 PERMIT NO. 011-130-11

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	2	2
Rock Boulder		2	5	3
Sand		5	10	5
Boulder		10	13	3
Cobles		13	30	17
Sand		30	35	5
Cobles		35	43	8
Sand		43	55	2
Cobles		55	60	5
Sand and Gravel		60	80	20
Cobles		80	90	10
Sand		90	100	
				35
Cobles		100	135	
Course sand		135	145	10
Cobles		145	165	20
Clay		165	170	.5
Rock ledge		170	180	10
Course sand cobles		180	200	20
Clay		200	205	5
Cobles and gravel		205	218	.3

8. WELL CONSTRUCTION  
 Depth Drilled 218 Feet Depth Cased 218 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 5/8 Inches 0 Feet 218 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	10	.188	+1	20
6.625	4.06	.316	20	180

Perforations:  
 Type perforation Factory cut  
 Size perforation .050  
 From 180 feet to 218 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 57  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 57 feet to 218 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ 128 feet below land surface  
 Artesian flow \_\_\_\_\_ N/A G.P.M. N/A P.S.I.  
 Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson & Sons Drilling, Inc.  
 (CONTRACTOR)

Date started August 15, 20 05  
 Date completed August 16, 20 05

7. WELL TEST DATE

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. <u>35</u>		<u>5</u>

Address 10760 Grass Valley Road  
 (CONTRACTOR)  
Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date Aug 18, 2005

RECEIVED  
 05 AUG 29 PM 1:42  
 STATE ENGINEERS OFFICE