


COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY



STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 97780

Permit No. _____

Basin 069

NOTICE OF INTENT NO. 55628

PRINT OR TYPE ONLY

1. OWNER **Dennis Acorda**
 MAILING ADDRESS 65 W. Railroad Street
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 455 Richards Road
Paradise Valley, NV

2. LOCATION ~~E 1/2~~ 1/4 SW 1/4 Sec 25 T 42 N R 39 E Humboldt County
 PERMIT NO. NE space #4 of 58 604-582-04 Cottonwood Estates
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	3	3
Clay		3	15	12
Cobles and sand		15	75	60
Sand and Gravel		75	100	25
Cobles and sand		100	105	5
Sand and gravel		105	150	45
Clay		150	155	5
Sand, fine gravel		155	170	15
Clay		170	173	3

*N 41.467866
 W 117.531213 NAD27*

plugged under NOT 59474

RECEIVED
 DENNIS ACORDA
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled 173 ~~172~~ Feet Depth Cased 167 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>173</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>188</u>	<u>+1</u>	<u>10</u>
<u>6.625</u>	<u>4.06</u>	<u>.316</u>	<u>10</u>	<u>147</u>

Perforations:
 Type perforation screen
 Size perforation 0.50
 From 147 feet to 167 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 167 feet

9. WATER LEVEL

Static water level 36 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson & Sons Drilling, Inc.
(CONTRACTOR)

Address 10760 Grass Valley Road
(CONTRACTOR)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 021467

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date August 20, 2005

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
	Draw Down (Feet Below Static)		Time (Hours)
G.P.M.	<u>20</u>		<u>4</u>