COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97782
Permit No.
Basin 105

NOTICE OF INTENT NO. 52329

1. OWNER JEFF KIRBY HOMES
MAILING ADDRESS 2972 SAN MATEO DR
NE MINDEN, NV 89423

ADDRESS AT WELL LOCATION 2566 MC KAY DR
MINDEN, NV 89423

2. LOCATION ~~NW~~ ¼ ~~NE~~ ¼ Sec 2 T 13 N R 20 E DOUGLAS County
PERMIT NO. DOM 05-028 NW (Issued by Water Resources) 1320-02-001-108 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLOW SANDS		0	6	6
DG SANDS		6	34	28
SMALL SANDS		34	89	55
BROWN CLAY		89	176	87
GRAY CLAY		176	265	89
SOFT SMALL SANDS	X	265	278	13
BROWN CLAY		278	299	21
SMALL SANDS AND CLAY	XXX	299	325	26

RECEIVED 05 AUG 31 AM 11:23 STATE ENGINEER'S OFFICE

Date started 8/9, 20 05
Date completed 8/15, 20 05

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10-11	85	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	325	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	25
sdr21 6 5/8	4.06	.216	25	325

Perforations:
Type perforation SAW CUT
Size perforation 3X3/32
From 245 feet to 265 feet
From 305 feet to 325 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 325 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M 10-11 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 8/24/05

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429