

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51401

1. OWNER Jimmie Lee
 MAILING ADDRESS HC33 Box 33585
Ely, Nevada 89301

ADDRESS AT WELL LOCATION Approximately 35
Miles NE of Ely

2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 28 T. 21 N. 64 E. White Pine County
 PERMIT NO. 66939
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-----------------------------------|--------------|------|-----|-----------|
| Top Soil | | 0 | 2 | 2 |
| Cement Sand & Small Gravel | | 2 | 25 | 23 |
| Hard Pan | | 25 | 35 | 10 |
| Cemented Sand & Small Gravel | | 35 | 70 | 35 |
| Sand & Gravel with Clay Stringers | | 70 | 90 | 20 |
| Brown Clay | | 90 | 95 | 5 |
| Sand & Course Gravel | | 95 | 110 | 15 |
| Sand & Small Gravel | | 110 | 145 | 35 |
| Water Bearing Course | X | 145 | 163 | 18 |
| Gravel With Clay Stringers | | 163 | 170 | 7 |
| Cemented Sand & Small Gravel | | 170 | 180 | 10 |
| Brown Clay | | 180 | 190 | 10 |
| Fine Sand | | 180 | 190 | 10 |
| Sand & Gravel with Clay Stringers | | 190 | 220 | 30 |
| Clay & Small Gravel | | 220 | 260 | 40 |
| Water Bearing Sand & Gravel | X | 260 | 270 | 10 |
| Clay with Gravel Stringers | | 270 | 310 | 40 |
| Brown Clay | | 310 | 320 | 10 |

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
20 Inches 0 Feet 320 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 16 | 42.05 | .250 | 0 | 280 |
| | | | | |
| | | | | |

Perforations:
 Type perforation Factory
 Size perforation 90 Slot 32 Rows
 From 119 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 280 feet

9. WATER LEVEL
 Static water level 141 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Contractor _____

Address 557 Ely Avenue
 Contractor _____
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rich Lewis By Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date August 15, 2005

Date started May 16 2005
 Date completed July 18 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| 600 | 130 | 4 |
| | | |
| | | |
| | | |

RECEIVED
 05 AUG 29 PM 1:37
 STATE ENGINEERS OFFICE