WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97793
Permit No.
Basin 105

NOTICE OF INTENT NO. 52234

1. OWNER Adams Family Trust, Elsie Adams Tructee
MAILING ADDRESS 2575 Jacks Valley Rd.
Minden, NV 89423

ADDRESS AT WELL LOCATION ~~2575~~ Jacks Valley Rd.
Ø

2. LOCATION NE 1/4 NW 1/4 Sec. 3 T 13N N/S R 19E E Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 1319-03-101-001 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil boulders				
coarse sand		0	15	15
Boulders 3/4" gravel		15	60	45
Hard volcanic rock		60	75	15
Boulder		75	80	5
Hard volcanic rock & boulders		80	115	35
Hard volcanic rock		115	143	28
Softer coarse sand	x	143	158	15
Boulders volcanic	x	158	165	7
Coarse sand & gravel	x	165	175	10
Hard rock & boulders	x	175	200	25
Volcanic gravel coarse sand boulders	x	200	238	38

Date started 8/3/2004, 19__
Date completed 8/6/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
90		3

8. WELL CONSTRUCTION
Depth Drilled 238 Feet Depth Cased 238 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	238	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	238

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 198 feet to 238 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 238 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2205
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8/18/2004

USE ADDITIONAL SHEETS IF NECESSARY