REPORT NO. A05.079

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 97833
PERMIT NO.
BASIN 104

NOTICE OF INTENT NO. 56022

1. OWNER Miya MacKenzie
MAILING ADDRESS 4130 Kings Canyon Rd. Carson City, NV
ADDRESS OF WELL 4130 Kings Canyon Rd.
Carson City, NV 89704

2. WELL LOCATION SW 1/4 SE 1/4 SEC. 14 T 15N R 19 E Carson City COUNTY

PERMIT NO ____ PARCEL NO 07-071-17 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dirt & gravels		0	15	15
Red clay & volcanic rock		15	25	10
Clay & cobbles		25	75	50
Boulders & clay		75	100	25
Green & black rock		100	115	15
Hard rock & clay		115	125	10
Gray clay, green & black rock		125	145	20
Gray clay & basalt		145	430	285
Black/green rock & clay		430	445	15
Gray clay & black rock		445	450	5
Black/gray rock & gray clay		450	475	25
Black rock & gray clay		475	480	5
Black basalt		480	495	15
Black rock & gray clay		495	508	13
Black/white/red/green rock & clay		508	525	17
Black/green rock & gray clay		525	555	30
Black rock, gray/brown clay		555	650	95
Black/red/green rock		650	655	5
Green/black rock		655	660	5
Black/white/red green rock	x	660	690	30
Green granite	x	690	730	40

Notes: The 6" casing was sealed at the bottom with neat cement.
Latitude: N39 degrees 9.440'
Longitude: W119 degreess 48.710'

Date Started 8/9/05 Date Completed 8/30/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1 hour

8. WELL CONSTRUCTION
Depth Drilled 730 Depth Cased 730

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 100 Feet
8 1/2 Inches 100 Feet 598 Feet
6 1/8 Inches 598 Feet 730 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	598
5	9.69	.188	590	730

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 690 Feet to 730 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [X] Pumped [ ] Poured
SEAL TYPE: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [ ] Yes [X] No
From ____ Feet to ____ Feet

9. WATER LEVEL
Static Water Level 140 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981
Signed Roger Mthady
By driller performing actual drilling on site or contractor
Dated August 30, 2005