COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97865
Permit No.
Basin 101

NOTICE OF INTENT NO. 55451

1. OWNER Jack Best
MAILING ADDRESS P.O. Box 6872
Fallon, NV 89406

ADDRESS AT WELL LOCATION ~~Jack Best~~
17477 Lahontan Dam Road
Fallon, NV 89406

2. LOCATION NW ¼ SE ¼ Sec 11 T 18 N R 26 E Churchill County

PERMIT NO. (Issued by Water Resources) | 006-122-66 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	15	15
Gravel		15	21	6
Brown Clay		21	75	54
Brown Sand		75	83	8
Brown Clay		83	100	17
Brown Clay		100	143	43
Sand & Gravel		143	175	32
Gravel & Sand		175	215	40
Brown Clay		215	230	15
Brown Clay		230	250	20
Black Clay & Sand		250	275	25
Black Sand		275	282	7
Black Rock	XX	282	320	38

Date started 8/3, 20 05
Date completed 8/6, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.25 Inches	0 Feet	100 Feet
10 Inches	100 Feet	320 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	6.625	0	20
6	3.85	.258	20	320

Perforations:
Type perforation Saw Cut
Size perforation .125
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 320 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 175 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2285
Signed
By driller performing actual drilling on site or contractor
Date 8/26/05

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com