WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97915
Permit No.
Basin 087

NOTICE OF INTENT NO. 56390

1. OWNER Evergreen Trailer Park, LLC.
MAILING ADDRESS 12955 South Virginia St.
Reno, NV 89511

ADDRESS AT WELL LOCATION Same as above

2. LOCATION NE 1/4 NE 1/4 Sec. 20 T 18N N/S R 20E E Washoe County
PERMIT NO. ~~n/a~~ 15747 (Issued by Water Resources) | 049-360-13 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 2 small submersible pumps from well. Measured static water level at 36.6' and depth of well at 120'. Installed 10" Mills Knife in well to 100' and perforated 5 rows per foot from 100' back to surface. There was no sanitary seal around casing because we could perforate casing. Installed 115' of 2" tremme pipe and mixed 70 bags of Portland Type II cement with approx 350 gallons of water and pumped in neat cement from bottom of well to surface. (copy of original log attached)				

RECEIVED

Date started 9/8/2005, 19__
Date completed 9/9/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 120' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	18 lbs.	.188"	+2	120'

Perforations:
Type perforation torch slot and Mills Knife
Size perforation
From 105 feet to 120 torch slot feet
From 100' feet to surface Mills Knife feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 120'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 36.6' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carsaon Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Trampe (By driller performing actual drilling on-site or contractor)
Date 9/12/2005

USE ADDITIONAL SHEETS IF NECESSARY