WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97916
Permit No.
Basin 104

NOTICE OF INTENT NO. 56716

1. OWNER Carson City Developement Services
MAILING ADDRESS 3505 Butti Way
Carson City, NV 89701

ADDRESS AT WELL LOCATION At the corner of Harbin and Musser Street, sherriffs parking lot in Carson City, NV.
610 Musser

2. LOCATION NW 1/4 SE 1/4 Sec. 17 T 15N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources
004-174-09 Parcel No.
Valley Park Addition Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mobilized to site and measured static water level at 6.13'. Measured depth of well at 16.5'. Well was constructed of 6" steel casing. 10' of perforated casing and 6' of blank. Installed tremme pipe and mixed 4 bags of Portland cement with 20 gallons of water and pumped in neat cement from bottom of well to surface.				

RECEIVED
2005 OCT 31 PM 2:33
STATE ENGINEERS OFFICE

Date started 10/26/2005, 19__
Date completed 10/26/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 16' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"			0'	16.5'

Perforations:
Type perforation slotted
Size perforation n/a
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 16.5'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 6.13' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump
Contractor
Address P.O. Box 20159
Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10/28/2005

USE ADDITIONAL SHEETS IF NECESSARY