WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97918
Permit No.
Basin 104

NOTICE OF INTENT NO. 56389

1. OWNER Preston Peterson
MAILING ADDRESS P.O. Box 43
Carson City, NV

ADDRESS AT WELL LOCATION 1345 Medical Parkway
Carson City, NV.

2. LOCATION NW 1/4 NW 1/4 Sec. 6 T 15N N/S R 20E E Carson County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mobilized to well and removed 210' of 1-1/4" pipe and submersible pump. Measured static water level at 51' and depth of well at 350'. Well had been deepened and did not match original well log. We installed perforator but could not advance past 105'. We decided that this is where the top of the liner is. We then raised perforator to 84' and cut 4 rows per foot from 84' to surface. There was intermittent concrete in the top 44'. We then installed 340' of 2" tremme and pumped in a full 4 yards of neat cement from the bottom of the well to the surface. Well volume should have required 2.5 yards. (original log attached)				
Plugging of log # 11847				

Date started 9/8/2005, 19__
Date completed 9/9/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188		

Perforations:
Type perforation Mills knife
Size perforation
From 84' feet to surface feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 350'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Tranger (By driller performing actual drilling on-site or contractor)
Date 10/18/2005

USE ADDITIONAL SHEETS IF NECESSARY