

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 97931  
 Permit No. \_\_\_\_\_  
 Basin 789

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **55296**

1. OWNER Ben Woods ADDRESS AT WELL LOCATION 3110 Whitepine Dr. (White Pine)  
 MAILING ADDRESS 3110 Whitepine Dr. Washoe Valley, NV 89704  
 2. LOCATION NW 1/4 NE 1/4 Sec. 06 T 16N N/S R 20E E Washoe County  
 PERMIT NO. 050-423-02 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand		0	20	20
Coarse sand DG		20	40	20
Gray clay & sand		40	45	5
Gray sand		45	80	35
Gray sand small rock		80	100	20
Gray sand clay		100	120	20
Gray sand gravel some clay		120	140	20
Gray sand gravel rock	x	140	160	20
Brown sand rock gravel some clay	x	160	180	20
Sand rock gravel	x	180	197	17

Washoe County Well Permit # WL 050230

8. WELL CONSTRUCTION  
 Depth Drilled 197 Feet Depth Cased 197 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 197 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	197

Perforations:  
 Type perforation Machine cut  
 Size perforation 3/32 x 3  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  Cement Grout  Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 197 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site for contractor  
 Date 10/13/2005

Date started 10/10/2005 19  
 Date completed 10/11/2005 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>		<u>3</u>