WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97933
Permit No.
Basin 091

NOTICE OF INTENT NO. 55372

1. OWNER Geoffrey House
MAILING ADDRESS 450 Leventina Canyon
Reno, NV 89523

ADDRESS AT WELL LOCATION 450 Leventina Canyon Rd.

2. LOCATION NE 1/4 NW 1/4 Sec. 22 T 19N N/S R 18E E Washoe County
PERMIT NO. Issued by Water Resources | 38-671-01 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" x 342' well by pumping 3.25 cu yards of neat cement mixed 5.2 gallons of water per sack. We pumped, using tremie pipe, from the bottom to the top of the well, 5 feet below grade. Due to existing perforations in the casing no perfortions were needed.				
WASHOE CO. PERMIT #WL050229				

Date started 10/13/2005 , 19__
Date completed 10/13/2005 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 342 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160
5	10.79	.188	135	342

Perforations:
Type perforation Factory sawed
Size perforation 3/32 x 3

From 120	feet to	160	feet
From 162	feet to	182	feet
From 242	feet to	262	feet
From 302	feet to	342	feet
From	feet to		feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 10/14/2005

USE ADDITIONAL SHEETS IF NECESSARY