COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97959
Permit No.
Basin 105

NOTICE OF INTENT NO. 52337

1. OWNER MIKE WILLIAMS CONSTRUCTION
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2026 ROCKING HORSE GARDNERVILLE, NV 89410

2. LOCATION ~~NE~~ SE ¼ ~~SW~~ NW ¼ Sec 19 T 12 N R 21 E DOUGLAS County

PERMIT NO. | Issued by Water Resources | 1221-19-001-013 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARDPAN CLAY		0	6	6
BROWN CLAY		6	34	28
COURSE GRAVELS		34	89	55
SMALL OBSIDIAN GRAVELS		89	152	63
BROWN CLAY STRATA		152	210	58
SMALL SANDS AND CLAY STRATAS		210	238	28
SMALL SANDS AND CLAY		238	265	27
BROWN CLAY		265	310	45
FRACTURED GRAVELS	XXX	310	355	45

Date started 10/21, 20 05
Date completed 10/28, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	85	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 355 Feet Depth Cased 355 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4	Inches	0 Feet	355 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	15
6 5/8 sdr 21	4.06	.216	15	355

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3X 3/32
From 315 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 355 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M 20 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLIG (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 10/28/05