WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97963
Permit No.
Basin 066

NOTICE OF INTENT NO. 55759

1. OWNER Newmont Mining Corp
MAILING ADDRESS P.O. Box 388 Valmy, NV 89438
ADDRESS AT WELL LOCATION Twin Creeks mine North of Golconda, NV

2. LOCATION SE ¼ NW ¼ Sec. 18 T. 39 N/S R. 43 E Humboldt County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. M/O 18-11 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium 0-85'				
Shale, oxide, sulfide and hard rock 85' - 1700				
H2O Incounter 1560' (First and only)				
Build well - Set well Casing - run Trimmy - Place 3/8 gravel in hole from 1700 to 1255'				
Place 3/8 Hole plug 1255 to 50'				
Pour in Cement for 50' Cap				
Set monument and Cap				
Develope well. Developed good.				
2-6 yrd³ gravel				
6-8 yrd³ 3/8 Hole plug				
65 gal Cement Slurry 1522				
N 41.262828 W. 117.175552 NAD27				
Plugged under NOI 61055				

Date started 10/6, 2005
Date completed 10/18, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4½		

8. WELL CONSTRUCTION
Depth Drilled 1700 Feet Depth Cased 1700 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
6⅛	20	1700
8¾	0	20

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2⅜		3/16	+3	-1697

Perforations:
Type perforation Slot
Size perforation ⅛
From 1257 feet to 1657 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 1255 feet to 1700 feet

9. WATER LEVEL
Static water level 1075 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co (Contractor)
Address P.O. Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed (By driller performing actual drilling on site or contractor)
Date 10/18/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627